

# **Long-Term Accelerated Aging Tests of the CTC Global Aluminum Conductor Composite Core Dublin Conductor**

*Final Results*

**3002009962**

---



# **Long-Term Accelerated Aging Tests of the CTC Global Aluminum Conductor Composite Core Dublin Conductor**

*Final Results*

**3002009962**

Technical Update, March 2017

EPRI Project Manager

G. Sibilant

## **DISCLAIMER OF WARRANTIES AND LIMITATION OF LIABILITIES**

THIS DOCUMENT WAS PREPARED BY THE ORGANIZATION(S) NAMED BELOW AS AN ACCOUNT OF WORK SPONSORED OR COSPONSORED BY THE ELECTRIC POWER RESEARCH INSTITUTE, INC. (EPRI). NEITHER EPRI, ANY MEMBER OF EPRI, ANY COSPONSOR, THE ORGANIZATION(S) BELOW, NOR ANY PERSON ACTING ON BEHALF OF ANY OF THEM:

(A) MAKES ANY WARRANTY OR REPRESENTATION WHATSOEVER, EXPRESS OR IMPLIED, (I) WITH RESPECT TO THE USE OF ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS DOCUMENT, INCLUDING MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, OR (II) THAT SUCH USE DOES NOT INFRINGE ON OR INTERFERE WITH PRIVATELY OWNED RIGHTS, INCLUDING ANY PARTY'S INTELLECTUAL PROPERTY, OR (III) THAT THIS DOCUMENT IS SUITABLE TO ANY PARTICULAR USER'S CIRCUMSTANCE; OR

(B) ASSUMES RESPONSIBILITY FOR ANY DAMAGES OR OTHER LIABILITY WHATSOEVER (INCLUDING ANY CONSEQUENTIAL DAMAGES, EVEN IF EPRI OR ANY EPRI REPRESENTATIVE HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES) RESULTING FROM YOUR SELECTION OR USE OF THIS DOCUMENT OR ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS DOCUMENT.

REFERENCE HEREIN TO ANY SPECIFIC COMMERCIAL PRODUCT, PROCESS, OR SERVICE BY ITS TRADE NAME, TRADEMARK, MANUFACTURER, OR OTHERWISE, DOES NOT NECESSARILY CONSTITUTE OR IMPLY ITS ENDORSEMENT, RECOMMENDATION, OR FAVORING BY EPRI.

**THE ELECTRIC POWER RESEARCH INSTITUTE (EPRI) PREPARED THIS REPORT.**

**This is an EPRI Technical Update report. A Technical Update report is intended as an informal report of continuing research, a meeting, or a topical study. It is not a final EPRI technical report.**

### **NOTE**

For further information about EPRI, call the EPRI Customer Assistance Center at 800.313.3774 or e-mail [askepri@epri.com](mailto:askepri@epri.com).

Electric Power Research Institute, EPRI, and TOGETHER...SHAPING THE FUTURE OF ELECTRICITY are registered service marks of the Electric Power Research Institute, Inc.

Copyright © 2017 Electric Power Research Institute, Inc. All rights reserved.

# ACKNOWLEDGMENTS

The Electric Power Research Institute (EPRI) prepared this report.

Principal Investigator

G. Sibilant

This report describes research sponsored by EPRI.

EPRI would like to acknowledge the support of CTC Global of Irvine, California. The tests were conducted by EPRI at its Charlotte, North Carolina laboratory under contract by CTC Global.

This work was done under a billable services agreement (BSA); as such, the information belongs to CTC Global who funded the work.

---

This publication is a corporate document that should be cited in the literature in the following manner:

*Long-Term Accelerated Aging Tests of the CTC Global Aluminum Conductor Composite Core Dublin Conductor: Final Results.* EPRI, Palo Alto, CA: 2017. 3002009962.



# ABSTRACT

This report details the hardware, test setup, test parameters, and results of accelerated thermal mechanical aging tests as well as the results of the post-aging tests conducted on an aluminum conductor composite core (ACCC) conductor and associated connectors. These tests were performed as a follow-up to the long-term aging tests previously conducted by EPRI and described in report 3002007503, *Accelerated Aging Tests of High-Temperature, Low-Sag (HTLS) Conductor Systems: Test Results*.

In the earlier set of tests, the ACCC conductor exhibited anomalous performance, which was suspected of being an artifact of the relatively short test span employed in the EPRI testing. For the current report, tests were conducted on two test spans, each approximately 90 ft (27 m) in length. All of the connectors that formed the various conductor test setups were installed by CTC Global staff in the EPRI laboratory.

## **Keywords**

ACCC conductor

AFL connectors

Burndy connectors

Post-thermal cycling tests

Thermal mechanical aging





# CONTENTS

<b>ABSTRACT .....</b>	<b>V</b>
<b>1 INTRODUCTION AND BACKGROUND .....</b>	<b>1-1</b>
Conductor Test Setup .....	1-1
Initial Setup .....	1-1
Long-Term Test Setup .....	1-2
Modified Long-Term Test Setup.....	1-2
Final Long-Term Test Setup .....	1-2
<b>2 CONDUCTOR AND CONNECTORS TESTED .....</b>	<b>2-1</b>
Test Conductor.....	2-1
Test Connectors.....	2-3
<b>3 MEASUREMENTS .....</b>	<b>3-1</b>
Temperature Measurements.....	3-1
Tension Measurements.....	3-2
Resistance Measurements.....	3-3
Radiography.....	3-3
<b>4 THERMAL MECHANICAL RESULTS OVERVIEW .....</b>	<b>4-1</b>
Test Protocol.....	4-1
Thermal and Tension Profiles .....	4-2
Resistance Profiles .....	4-4
<b>5 POST-THERMAL CYCLING TESTS AND RESULTS .....</b>	<b>5-1</b>
Tests Undertaken.....	5-1
Conductor Tensile Tests .....	5-1
Connector Tensile Tests .....	5-2
Glass Temperature ( $T_g$ ) Transition Tests.....	5-11
Core Shear Tests.....	5-12
Core Tensile Tests.....	5-13
<b>6 CONDUCTOR AND CONNECTORS .....</b>	<b>6-1</b>
<b>A RADIOGRAPHS OF AFL SPLICES .....</b>	<b>A-1</b>
Splice 1 – 0 Cycles.....	A-1
Splice 1 – 1500 Cycles.....	A-2
Splice 2 – 0 Cycles.....	A-3
Splice 2 – 1500 Cycles.....	A-4
<b>B RADIOGRAPHS OF AFL DEAD-ENDS .....</b>	<b>B-1</b>
Dead-end 1 .....	B-1
Dead-end 2 .....	B-2
<b>C RADIOGRAPHS OF BURNDY SPLICES.....</b>	<b>C-1</b>
Splice 1 – 0 Cycles.....	C-1

Splice 1 – 1500 Cycles.....	C-2
Splice 2 – 0 Cycles.....	C-3
Splice 2 – 1500 Cycles.....	C-4
<b>D RADIOGRAPHS OF BURNDY DEAD-ENDS.....</b>	<b>D-1</b>
Dead-end 1 – 0 Cycles.....	D-2
Dead-end 1 – 1500 Cycles.....	D-3
Dead-end 2 – 0 Cycles.....	D-4
Dead-end 2 – 1500 Cycles.....	D-5

## LIST OF FIGURES

Figure 3-1 Thermocouple in drilled hole .....	3-1
Figure 3-2 Example of the thermocouple placement .....	3-2
Figure 3-3 In-line load cells .....	3-2
Figure 4-1 Conductor surface thermal profiles for three thermal cycles .....	4-1
Figure 4-2 Conductor tension profiles for three thermal cycles .....	4-2
Figure 4-3 Line 6 thermal profiles and tension: Burndy connectors.....	4-3
Figure 4-4 Line 7 thermal profiles and tension: AFL connectors .....	4-3
Figure 4-5 Line 6 resistance profiles .....	4-5
Figure 4-6 Line 7 resistance profiles .....	4-6
Figure 5-1 Conductor sample in tensile test bed .....	5-2
Figure 5-2 Conductor pullout from the Epoxy Fitting – AFL new splice .....	5-3
Figure 5-3 Conductor pullout on left hand side of splice – AFL splice 1 .....	5-4
Figure 5-4 Conductor pullout on both sides of splice – AFL splice 2 .....	5-4
Figure 5-5 Epoxy conductor slippage – AFL new dead-end .....	5-5
Figure 5-6 Conductor break – AFL dead-end 1 .....	5-5
Figure 5-7 Conductor pulled out of dead-end – AFL dead-end 2 .....	5-6
Figure 5-8 Conductor break in epoxy fitting – Burndy new splice .....	5-7
Figure 5-9 Conductor pulled out of splice – Burndy splice 1.....	5-7
Figure 5-10 Conductor break – Burndy splice 2 .....	5-8
Figure 5-11 Conductor broke just out of epoxy fitting and seating in fitting – Burndy new dead-end.....	5-9
Figure 5-12 Conductor break – Burndy dead-end 1 .....	5-9
Figure 5-13 Conductor break – Burndy dead-end 2 .....	5-10
Figure 5-14 Breaking loads.....	5-10
Figure 5-15 DMA scan (arrow indicates the Maximum Loss Modulus [E'']) .....	5-11
Figure 5-16 Physical representation of three-point bending test .....	5-12
Figure 6-1 Two ACCC conductors after 1500 cycles (the two conductors on the right hand side) .....	6-1
Figure 6-2 Burndy and AFL dead-ends (in the foreground) after 1500 cycles.....	6-2
Figure 6-3 Burndy and AFL splices (in the foreground) after 1500 cycles.....	6-3



## LIST OF TABLES

Table 2-1 Conductor used in the tests .....	2-1
Table 2-2 Conductor specifications.....	2-2
Table 2-3 Burndy connectors used in the tests.....	2-3
Table 2-4 AFL connectors used in the tests .....	2-4
Table 5-1 Conductor Tensile Strength .....	5-1
Table 5-2 AFL Connector Tensile Strength .....	5-2
Table 5-3 Burndy Connector Tensile Strength.....	5-6
Table 5-4 Core $T_g$ Values.....	5-12
Table 5-5 Core Shear Strength.....	5-12
Table 5-6 Core Tensile Strength.....	5-13



# 1

## INTRODUCTION AND BACKGROUND

The CTC Global aluminum conductor composite core (ACCC) conductor was tested at the EPRI facility in Charlotte, North Carolina. These tests were done as a follow-up to the long-term aging tests previously conducted by EPRI and described in report 3002007503, *Accelerated Aging Tests of High-Temperature, Low-Sag (HTLS) Conductor Systems: Test Results*.

In the earlier set of tests, the ACCC conductor exhibited anomalous performance, which was suspected of being an artifact of the relatively short test span employed in the EPRI testing. For the current report, tests were conducted on two test spans, each approximately 90 ft (27 m) in length. All of the connectors that formed the various conductor test setups were installed by CTC Global staff in the EPRI laboratory.

### Conductor Test Setup

Four conductor test configurations were set up as follows:

1. Initial setup
  - a. Test span (splices and dead-ends)
  - b. Return span with no splices
2. Long-term setup
  - a. Second test span (splices and dead-ends)
  - b. Return span: line with no splices; same as used in initial setup
3. Modified long-term setup
  - a. Second test span: left from Test Setup 2
  - b. Return span removed; a new span with splices and dead-ends installed
4. Final long-term setup
  - a. Both test spans from the modified long-term setup removed
  - b. Test Span 1: Burndy splices and dead-ends
  - c. Test Span 2: AFL splices and dead-ends

All test spans were approximately 90 ft (27 m) in length, and the connectors were installed as recommended by the manufacturer unless otherwise noted.

### Initial Setup

One test span was made up of two dead-ends and two splices; the second test span (the return span) was made up of two dead-ends only. The splices and dead-ends in both spans were installed according to the manufacturer's instructions.

Thermal analysis was undertaken before and after pre-stressing the test conductor span. This was done to determine whether the pre-stressing would have an effect on the initial thermal and mechanical performance of the conductor and connectors in the test.

The thermal analysis consisted of subjecting the conductor to a series of controlled power levels while measuring temperature at several points on the hardware fittings as well as several points along the conductor. The test line was tensioned to 25% of the conductor's rated breaking strength (RBS).

At the completion of the initial thermal analysis, the test line was tensioned to 18,000 lbf (80,068 newton) or 44% of the conductor's RBS and left overnight at this tension. The return line (line without splices) was not pre-tensioned.

The next day, the tension was lowered to the test tension of 25% of the conductor's RBS, and another set of thermal analysis test cycles was performed on the conductor. The thermal and tension profiles measured before and after pre-stressing were compared to one another. The test line was then removed from the test setup; the return line was left in the test setup.

### **Long-Term Test Setup**

For the long-term setup, the return span (no splices) was left in the test frame. A new test span was installed and consisted of two dead-ends and two splices. The test span was not pre-stressed; it was tensioned to 25% of the conductor's RBS.

### **Modified Long-Term Test Setup**

For the modified long-term setup, the test span was kept in the test frame, but a spliced return span was installed—this test span replaced the return span with no splices. The test span consisted of two dead-ends and two splices. The test span was pre-stressed to 44% of the conductor's RBS and left overnight. The next day, the tension was reduced to 25% of the conductor's RBS.

### **Final Long-Term Test Setup**

For the final long-term setup, both test spans that formed part of the modified long-term setup were removed. Two new test spans were installed: one had Burndy splices and dead-ends installed; the other had AFL splices and dead-ends installed. The Burndy connectors were installed using a modified procedure, while the AFL connectors were installed according to the manufacturer's instructions.

The Burndy mechanical connectors were installed with a modified pressing procedure. The unpressed connector's pressing section lengths are 14 in. (356 mm) on each side of the splice. The connectors were forward pressed from 10 in. (254 mm) from the mouth, and the remaining 4 in. (102 mm) were reversed pressed. The modified pressing procedure was followed to replicate the strand behavior of the AFL hardware and extrude an equal amount of outer aluminum strands into the test span.



# 2

## CONDUCTOR AND CONNECTORS TESTED

The test conductor and connectors that formed part of the tests are described in this section.

### Test Conductor

The conductor used in the tests was the ACCC Dublin conductor, which was stranded by Lamifil in Europe. The conductor's outer diameter is similar to that of the Drake aluminum conductor steel-reinforced (ACSR) diameter; however, the equivalent aluminum area of the ACCC conductor is larger. Information on the conductor used in the tests is shown in Table 2-1, and the conductor specifications are listed in Table 2-2.

**Table 2-1**  
**Conductor used in the tests**

Company	Conductor Name	Description
CTC	Aluminum conductor composite core (ACCC): Dublin	1350: Fully annealed aluminum outer strands; composite carbon core



**Table 2-2  
Conductor specifications**

Conductor		LF ACCC 540mm <sup>2</sup>			
Code name		ACCC Dublin			
Mechanical specifications		Metric (SI)		Imperial	
Nominal aluminium equivalent area	mm <sup>2</sup>	546,4		in <sup>2</sup>	0,847
Nominal cross sectional area of aluminium	mm <sup>2</sup>	528,8		in <sup>2</sup>	0,820
Nominal cross-sectional area of core	mm <sup>2</sup>	71,3		in <sup>2</sup>	0,110
Number, diameter and type of central wire	#, mm	1	9,53 R	CC	#, in 1 0,375 R CC
Number, (eq.) diameter and type of wire in layer	#, mm	8	5,53 T	Al	#, in 8 0,218 T Al
Number, (eq.) diameter and type of wire in layer	#, mm	14	5,54 T	Al	#, in 14 0,218 T Al
Diameter tolerance of Composite Core (CC)	mm	± 0,05		in	± 0,002
Diameter tolerance of aluminium wires (Al or Alloy)	mm	± 0,03		in	± 0,001
Minimum filling factor of the aluminium cross section	%	93		%	93
Lay ratio of inner layer(s)		10-16			10-16
Lay ratio of outer layer		10-14			10-14
Overall diameter	mm	28,15		in	1,108
Diameter of core	mm	9,53		in	0,375
Rated tensile strength of conductor (RTS as per ASTM B 857) *	kN	183,5		klbf	41,3
Extreme load safety strength of conductor (with 40% of the aluminium strength) **	kN	166,2		klbf	37,4
Rated tensile strength of core	kN	153,8		klbf	34,6
Nominal mass per unit length - total	kg/km	1594,8		lb/kft	1071,7
Nominal mass per unit length - aluminium	kg/km	1463,0		lb/kft	983,1
Nominal mass per unit length - core	kg/km	132		lb/kft	89
Coefficient of linear expansion above thermal kneepoint	/ K	0,00000161		/ °F	0,00000089
Coefficient of linear expansion below thermal kneepoint	/ K	0,0000185		/ °F	0,00001027
Modulus of elasticity of the core	GPa	112,3		Msi	16,29
Modulus of elasticity below thermal kneepoint	GPa	63,2		Msi	9,16
Geometric mean radius	mm	11,47		ft	0,0376
Electrical specifications		Metric (SI)		Imperial	
Nominal DC resistance at 20 °C (tolerance ± 2%)	Ohm/km	0,0530		Ohm/mile	0,0853
Temperature coefficient		0,00403			0,00403
Frequency	Hz	50		Hz	60
Nominal AC resistance at 20 °C (tolerance ± 2%)	Ohm/km	0,0539		Ohm/mile	0,0873
Nominal AC resistance at 25 °C (tolerance ± 2%)	Ohm/km	0,0549		Ohm/mile	0,0890
Nominal AC resistance at 50 °C (tolerance ± 2%)	Ohm/km	0,0602		Ohm/mile	0,0974
Nominal AC resistance at 75 °C (tolerance ± 2%)	Ohm/km	0,0655		Ohm/mile	0,1059
Nominal AC resistance at 100 °C (tolerance ± 2%)	Ohm/km	0,0708		Ohm/mile	0,1144
Nominal AC resistance at 125 °C (tolerance ± 2%)	Ohm/km	0,0761		Ohm/mile	0,1228
Nominal AC resistance at 150 °C (tolerance ± 2%)	Ohm/km	0,0814		Ohm/mile	0,1314
Nominal AC resistance at 175 °C (tolerance ± 2%)	Ohm/km	0,0867		Ohm/mile	0,1399
Nominal AC resistance at 200 °C (tolerance ± 2%)	Ohm/km	0,0920		Ohm/mile	0,1484
Maximum allowable continuous operating temperature (surface)	°C	175		°F	347
Maximum allowable continuous operating temperature (core)	°C	180		°F	356
Emergency operating temperature (core)	°C	200		°F	392
Inductive reactance: X <sub>a</sub> (conductor part)	Ohm/km	0,2061		Ohm/mile	0,3980
Shunt capacitive reactance: X' <sub>a</sub> (conductor part)	MOhmkm	0,1761		MOhmmile	0,0912
Individual wires		Metric (SI)		Imperial	
Maximum resistivity of aluminium at 20 °C, minimum IACS	nOhmm, %	27,35	63%	nOhmft, %	89,73 63%
Minimum tensile strength, aluminium wire	MPa	58,6		psi	8500

## Test Connectors

Two different connectors were used in these tests. One set of connectors was manufactured by Burndy; information on these connectors is listed in Table 2-3. The second set of connectors was manufactured by AFL Global; information on these is given in Table 2-4.


**Table 2-3**  
**Burndy connectors used in the tests**

Conductor	Connector Manufacturer	Connector Description
ACCC (CTC)	Burndy	The connectors use a collet gripping system to mechanically connect to the core of the conductor. No compression grip is used on the core. A sleeve is inserted between the conductor aluminum strands and the outer aluminum housing, and then the outer housing is compressed onto the conductor.



**Table 2-4**  
**AFL connectors used in the tests**

Conductor	Connector Manufacturer	Connector Description
ACCC (CTC)	AFL Global	Two-stage compression connector. An extra sheath is placed on the core section inside the connector before the core grip piece is crimped onto the conductor core.




# 3

## MEASUREMENTS

Temperature and tension measurements were monitored continuously during the tests. Resistance measurements were taken periodically, initially every 100–150 cycles and later at 50-cycle intervals.

### Temperature Measurements

All temperature measurements were made using K-type temperature probes (thermocouples). Measurements were made by drilling a hole in the surface to be measured (connector or conductor) and then placing the temperature-sensitive thermocouple tip inside the drilled hole. Once the thermocouple tip was inserted into the hole, the hole was peened closed. An example of the thermocouple inserted into a connector is shown in Figure 3-1.



**Figure 3-1**  
**Thermocouple in drilled hole**

Thermocouples were placed on all connectors included in the tests. Temperature measurements were also made at the conductor/connector interface. Temperature measurements were taken every 5 minutes and stored in the control and data acquisition computer system.

All of the connectors had more than one thermocouple measurement point, and data were collected from all of these thermocouples. An example of the thermocouple placement on one connector can be seen in Figure 3-2.




**Figure 3-2**  
**Example of the thermocouple placement**

A connector in a healthy condition should have a temperature profile that is well below that of the conductor's temperature profile. In these tests, a connector would be classified as having failed the test if its temperature exceeds that of the conductor.

**Tension Measurements**

Each conductor was connected mechanically to the test frame by an insulator bell to provide electrical isolation. A calibrated load cell was connected in series between the insulator and the test frame; the configuration is shown in Figure 3-3.



**Figure 3-3**  
**In-line load cells**

The conductors were tensioned to 25% of their RBS as specified by the manufacturers. The change in tension during the thermal tests was recorded every 5 minutes and stored in the data acquisition system.

### **Resistance Measurements**

Resistance measurements were taken at regular intervals. An initial baseline measurement was made before the tests started. The first few resistance measurements were done in 150–200 cycle intervals.

A properly made, new connector would have a resistance value lower than that of the same length conductor. A connector would fail these tests if the resistance of the connector exceeded that of the conductor.

### **Radiography**

All connectors were radiographed before the thermal cycling tests began and again after the 1500 cycles had been completed.





# 4


## THERMAL MECHANICAL RESULTS OVERVIEW

### Test Protocol

The CTC Global ACCC conductor was tested at the EPRI facility in Charlotte. Two spans, each approximately 90 ft (27 m) in length, were tested. Each span had two dead-ends and two splices with about 30 ft (9 m) of separation between each connector in series. One test span had AFL compression connectors installed; the other had Burndy (collet-type) connectors installed.


The test plan called for the completion of 1500 thermal mechanical cycles. Each cycle lasted for approximately 5 hours and consisted of a heating period, a period of constant temperature, and a cooldown period.

The test control temperature was set to the maximum continuous operating temperature on the surface of the conductor: 180°C. Surface temperature profiles for the two spans for three thermal cycles are shown in Figure 4-1.



**Figure 4-1**  
Conductor surface thermal profiles for three thermal cycles

The conductor was initially tensioned at 25% of its RBS. The tension was not held constant but was allowed to vary as the conductor heated up and cooled down during each cycle. The test lines were re-tensioned if the tension measured at the end of the cooling period was lower than 20% of the conductor's RBS. Tension profiles for both test lines are shown in Figure 4-2.



**Figure 4-2**  
**Conductor tension profiles for three thermal cycles**

The 1500 thermal mechanical cycles testing was completed at 4:04 pm on November 13, 2016.

### **Thermal and Tension Profiles**

The 1500-cycle thermal and tension profiles for the two test lines are shown in Figures 4-3 and 4-4.




Figure 4-3  
Line 6 thermal profiles and tension: Burndy connectors




Figure 4-4  
Line 7 thermal profiles and tension: AFL connectors

The initial line temperature control was linked to the green thermocouple data set; however, it was later changed to a more accurate thermocouple arrangement, which is shown in the brown data set. A similar change was made on Line 7, where the more accurate brown data points are more visible.

The line tension for Line 6 has dropped from the initial tension of 10,325 lb (4683 kg) (25% RBS) down to 9357 lb (4244 kg). This lower value is approximately 22.8% of the conductor's RBS. The conductor span was not re-tensioned during the 1500 test cycles.

The connector temperatures were generally below 100°C. The splice surface temperatures were found to be higher than the dead-end surface temperatures.


The initial line temperature control was linked to the green thermocouple data set; however, it was later changed to a more accurate thermocouple arrangement, which is shown in the brown data set.

The line tension for Line 7 has dropped from the initial tension of 10,325 lb (4683 kg) (25% RBS) down to 9324 lb (4229 kg). This lower value is approximately 22.7% of the conductor's RBS. The conductor span was not re-tensioned during the 1500 test cycles.


The connector temperatures were generally below 105°C. The splice surface temperatures were found to be higher than the dead-end surface temperatures.

## **Resistance Profiles**

The 1500-cycle thermal and tension profiles for the two test lines are shown in Figures 4-5 and 4-6. From these figures, it can be seen that the resistance values for the connectors were stable. The resistance values did not increase much during the thermal cycles for almost all of the connectors in the test. The one exception was Line 6: DE1, a Burndy dead-end. This connector experienced a 10  $\mu\Omega$  increase in its resistance value (that is, a 43.5% increase).



**Figure 4-5**  
**Line 6 resistance profiles**



**Figure 4-6**  
**Line 7 resistance profiles**

# 5

## POST-THERMAL CYCLING TESTS AND RESULTS

### Tests Undertaken

At the end of the 1500 thermal mechanical test cycles the test spans were cut into pieces and sent to the CTC facility for testing, the following tests were done:

1. Conductor Tensile Tests
2. Connector Tensile Tests
3. Glass Temperature Transition
4. Core Shear Strength
5. Core Tensile Tests

All post thermal cycling tests were done at the CTC facility in Irvine California. An EPRI representative witnessed the testing.

### Conductor Tensile Tests

An aged section of the conductor was tensile tested to determine the residual strength left after thermal-mechanical aging. A new conductor sample was also tested, this was done to get a baseline strength which the aged sample strength could be compared against. The manufacturer's rated breaking strength was given as 41,200 lbs. The aged conductors and connectors tested had to equal or exceed 95% (39140 lbs) of the manufacturer's rated breaking strength for a new conductor. The results of the tests are shown in Table 5-1:

**Table 5-1**  
**Conductor Tensile Strength**

Sample	Breaking Load in lbs	% RBS
Unaged Conductor	42367	102.8
Aged Conductor	48763	118.4

From the results in Table 3-1 it can be seen that both the aged and unaged conductor sample broke at loads above the RBS. Similar tests done on other HTLS conductors have shown a similar trend, i.e. the aged sample breaks at a higher load than the unaged sample. A photograph showing a conductor sample in the tensile test bed is shown in Figure 5-1.



**Figure 5-1**  
**Conductor sample in tensile test bed**

**Connector Tensile Tests**

All the connectors which formed part of the tests were tensile tested to determine the residual strength left after thermal-mechanical aging. New connector samples were also tested, this was done to get a baseline strength which the aged samples strengths could be compared against. Connector strength is rated at 95% of the conductors RBS.

The results of the AFL Connector tensile tests are shown in Table 5-2:

**Table 5-2**  
**AFL Connector Tensile Strength**


<b>Sample</b>	<b>Breaking Load in lbs</b>	<b>% RBS</b>	<b>Notes</b>
New AFL Splice	39977	97.0	Conductor pulled out of Epoxy Grip
Aged AFL Splice 1	47758	115.9	Splice Pullout
Aged AFL Splice 2	47921	116.3	Conductor Break
New AFL Dead-end	37746	91.6	Conductor pulled out of Epoxy Grip
Aged AFL Dead-end 1	47488	115.3	Conductor Break
Aged AFL Dead-end 2	48385	117.4	DE Pullout

From Table 5-2 it can be noted that the New Splice and Dead-end samples pulled out of the epoxy resin end fittings below the 100% rated strength. The conductor did not break, nor did the conductor slip out of the splice or dead-end. The AFL epoxy resin end fittings for the new samples were the first to be cured. It is believed that the curing was not completed properly which led to the lower slip epoxy slip out values. All the aged fittings exceeded 115% of the conductors rated breaking strength. Images of the AFL samples tested are shown in Figure 5-1 to Figure 5-7.






**Figure 5-2**  
**Conductor pullout from the Epoxy Fitting – AFL new splice**



**Figure 5-3**  
Conductor pullout on left hand side of splice – AFL splice 1



**Figure 5-4**  
Conductor pullout on both sides of splice – AFL splice 2



**Figure 5-5**  
**Epoxy conductor slippage – AFL new dead-end**



**Figure 5-6**  
**Conductor break – AFL dead-end 1**




**Figure 5-7**  
**Conductor pulled out of dead-end – AFL dead-end 2**

The results of the Burndy Connector tensile tests are shown in Table 5-3:

**Table 5-3**  
**Burndy Connector Tensile Strength**

Sample	Breaking Load in lbs	% RBS	Notes
New Burndy Splice	43703	106.1	Conductor broke in Epoxy fitting
Aged Burndy Splice 1	45761	111.1	Conductor slipped out of fitting
Aged Burndy Splice 2	45785	111.1	Conductor broke
New Burndy Dead-end	43064	104.5	Conductor broke just out of epoxy fitting
Aged Burndy Dead-end 1	46591	113.1	Conductor broke
Aged Burndy Dead-end 2	45623	110.7	Conductor broke

From Table 5-3 it can be noted that all the Burndy unaged and aged fittings exceeded 100% of the conductors rated breaking strength. It is interesting to note that the aged fittings had higher breaking strengths than the unaged samples. Images of the Burndy samples being tested are shown in Figure 5-8 to Figure 5-13.




**Figure 5-8**  
Conductor break in epoxy fitting – Burndy new splice



**Figure 5-9**  
Conductor pulled out of splice – Burndy splice 1



**Figure 5-10**  
**Conductor break – Burndy splice 2**



**Figure 5-11**  
Conductor broke just out of epoxy fitting and seating in fitting – Burndy new dead-end




**Figure 5-12**  
Conductor break – Burndy dead-end 1



**Figure 5-13**  
**Conductor break – Burndy dead-end 2**

The breaking loads for the conductor and AFL and Burndy connectors are represented graphically in Figure 5-14.




**Figure 5-14**  
**Breaking loads**



## Glass Temperature ( $T_g$ ) Transition Tests

This test determines the temperature at which the properties of the composite core materials of the conductor change. It provides an indication of the maximum allowable operating temperature of the conductor. The test uses dynamic mechanical analysis (DMA) to determine the glass transition temperature ( $T_g$ ) of the composite materials. The test follows, as closely as possible, the procedure described in ASTM D7028-07 [3] and IEC 1006 [4] standards. Figure 5-15 shows an example of a DMA scan. The  $T_g$  is taken to be the temperature of the maximum loss modulus ( $E''$ ) – indicated by the arrow in Figure 5-15. The initial and final  $T_g$  temperatures were measured using the same test method.



**Figure 5-15**  
DMA scan (arrow indicates the Maximum Loss Modulus [ $E''$ ])


Typically  $T_g$  values for new samples are above the maximum operating temperature of the conductor. The  $T_g$  test results are shown in Table 5-4:

**Table 5-4**  
**Core  $T_g$  Values**

Sample	$T_g$ in °C	Delta T from New $T_g$ in °C
Line 6	212.5	16.2
Line 7	212.6	16.1
New	228.7	-

### Core Shear Tests

This test determines a secondary mechanical characteristic of the conductor core. The cores are characterized by a three-point bending test that induces a shear failure. The initial and final mechanical characteristics were assessed with the same protocol.



**Figure 5-16**  
**Physical representation of three-point bending test**

The results of the shear tests are shown in Table 5-5. e.

**Table 5-5**  
**Core Shear Strength**

Sample	Line 6 - Burndy	Line 7 - AFL	New - Control
1	37.20	32.11	45.37
2	35.82	39.95	45.86
3	38.51	34.03	46.32
4	39.28	35.54	39.71
5	39.14	32.22	40.62
<b>Average</b>	37.99	34.77	43.58
<b>Standard Deviation</b>	1.47	3.22	3.15
<b>% Difference from Control sample</b>	12.8	20.2	-

## Core Tensile Tests

An aged section of the conductor core was tensile tested to determine the residual strength left after thermal-mechanical aging. A new conductor core sample was also tested, this was done to get a baseline strength which the aged sample strength could be compared against. The results of the core tensile tests are shown in Table 5-6.

**Table 5-6**  
**Core Tensile Strength**

<b>Sample</b>	<b>Tensile Strength (Ksi)</b>	<b>Tensile Strength (Mpa)</b>
Line 6	319.66	2,206.04
Line 7	325.68	2,245.45
New	328.96	2268.13



# 6

## CONDUCTOR AND CONNECTORS

The physical condition of the conductor and connectors has not changed significantly from when they were installed. There has been no loosening of the aluminum strands, nor has there been and slippage of the conductor in the connectors. Images of the two conductor spans and some connectors are shown in Figure 6-1, Figure 6-2, and Figure 6-3.



**Figure 6-1**  
**Two ACCC conductors after 1500 cycles (the two conductors on the right hand side)**



**Figure 6-2**  
**Burndy and AFL dead-ends (in the foreground) after 1500 cycles**



**Figure 6-3**  
**Burndy and AFL splices (in the foreground) after 1500 cycles**






# A


## RADIOGRAPHS OF AFL SPLICES

The physical condition of the conductor and connectors has not changed significantly from when they were installed.


### Splice 1 – 0 Cycles




Splice 1 – 1500 Cycles



Splice 2 – 0 Cycles



Splice 2 – 1500 Cycles




# B


## RADIOGRAPHS OF AFL DEAD-ENDS

The physical condition of the conductor and connectors has not changed significantly from when they were installed.

### Dead-end 1



**Dead-end 2**




# C


## RADIOGRAPHS OF BURNDY SPLICES

The physical condition of the conductor and connectors has not changed significantly from when they were installed.

### Splice 1 – 0 Cycles




Splice 1 – 1500 Cycles






Splice 2 – 0 Cycles



Splice 2 – 1500 Cycles




# ***D***


## **RADIOGRAPHS OF BURNDY DEAD-ENDS**

The physical condition of the conductor and connectors has not changed significantly from when they were installed.


Dead-end 1 – 0 Cycles




Dead-end 1 – 1500 Cycles



Dead-end 2 – 0 Cycles



Dead-end 2 – 1500 Cycles









## **Export Control Restrictions**

Access to and use of EPRI Intellectual Property is granted with the specific understanding and requirement that responsibility for ensuring full compliance with all applicable U.S. and foreign export laws and regulations is being undertaken by you and your company. This includes an obligation to ensure that any individual receiving access hereunder who is not a U.S. citizen or permanent U.S. resident is permitted access under applicable U.S. and foreign export laws and regulations. In the event you are uncertain whether you or your company may lawfully obtain access to this EPRI Intellectual Property, you acknowledge that it is your obligation to consult with your company's legal counsel to determine whether this access is lawful. Although EPRI may make available on a case-by-case basis an informal assessment of the applicable U.S. export classification for specific EPRI Intellectual Property, you and your company acknowledge that this assessment is solely for informational purposes and not for reliance purposes. You and your company acknowledge that it is still the obligation of you and your company to make your own assessment of the applicable U.S. export classification and ensure compliance accordingly. You and your company understand and acknowledge your obligations to make a prompt report to EPRI and the appropriate authorities regarding any access to or use of EPRI Intellectual Property hereunder that may be in violation of applicable U.S. or foreign export laws or regulations.

**The Electric Power Research Institute, Inc.** (EPRI, [www.epri.com](http://www.epri.com)) conducts research and development relating to the generation, delivery and use of electricity for the benefit of the public. An independent, nonprofit organization, EPRI brings together its scientists and engineers as well as experts from academia and industry to help address challenges in electricity, including reliability, efficiency, affordability, health, safety and the environment. EPRI members represent 90% of the electric utility revenue in the United States with international participation in 35 countries. EPRI's principal offices and laboratories are located in Palo Alto, Calif.; Charlotte, N.C.; Knoxville, Tenn.; and Lenox, Mass.

Together...Shaping the Future of Electricity